

Certificate of Compliance

Certificate Number **20050314-MH29794**
Report Reference **MH29794, 2004 November 30**
Issue Date **2005 March 14**

Page 1 of 1



Issued to: **Chip Ngai Engineering Works Sdn. Bhd.**
Lot 7907, Jalan Balakong Batu 11, 43300 Seri Kembangan, Selangor, Malaysia


This is to certify that representative samples of **Underground Flammable Liquid Tanks**
Jacketed underground tanks for flammable liquids

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 1746, External Corrosion Protection Systems for Steel Underground Storage Tanks**

Additional Information: This category covers tanks intended for the underground storage of flammable and combustible liquids at atmospheric pressure. These tanks are intended for installation and use in accordance with NFPA 30, "Flammable and Combustible Liquids Code" and NFPA 31, "Standard for the Installation of Oil-Burning Equipment."

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Wayne Doversberger

Reviewed by:

Carson Wang

Wayne Doversberger / Staff Engineer

Carson Wang / Operation Manager

UL International Ltd. - Hong Kong

UL International Ltd. - Hong Kong

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International Ltd.
For questions in Hong Kong, you may call 22769000.